

**OFFICE OF THE EXECUTIVE ENGINEER  
P. H. DIVISION, MUZAFFARPUR**

Letter No. : .....1760...../


Dated : ...04-08-2023.

**REGARDING SAFE DRINKING WATER AND SNAITARY CONDISION**


**CERTIFICATE**


It is certified that an inspection team headed by Sri Jitendra Kumar, Chemist from Public Health Division, Muzaffarpur (Name of Department/Office) inspected the PRABHAT TARA SCHOOL, Chakkar Maidan, P. S. – Kazi Mohammadpur Thana, District – Muzaffarpur, Bihar – 842001 (Name of School) has safe drinking water facilities for the students and memories of staff of the institution and is maintaining the hygienic by the central/state/U.T. Govt.

The above is valid for a period of One Year.

  
04/08/2023  
Chemist

R. W. T. L., Muzaffarpur


  
04/08/23

  
Executive Engineer,  
P. H. Division, Muzaffarpur

To,

The Principal,  
Prabhat Tara School,  
Chakkar Maidan,  
P. S. – Kazi Mohammadpur Thana,  
Dist. – Muzaffarpur,  
Bihar - 842001

  
Principal  
Prabhat Tara School  
Chakkar, Muzaffarpur

  
MANAGER  
PRABHAT TARA SCHOOL  
CHAKKAR MAIDAN  
MUZAFFARPUR-842001  
(BIHAR)

PUBLIC HEALTH ENGINEERING DEPARTMENT

Water Quality Report

Division Name :- P. H. Division, Muzaffarpur

District Name : Muzaffarpur

Month : August 2023

Name of the School :- PRABHAT TARA SCHOOL, MUZAFFARPUR

Sl. No.	Testing Date	Block	Panchayat	Village	Habitat/Ward	Location of Source	pH	Turb	Cond	TDS	TH	Ca	Mg	Cl	Alk	Fe	No <sub>3</sub>	So <sub>4</sub>	F	As	Total Cell	Remarks
1	02.08.2023	Mushari	-	-	-	Chakkar Maidan, Muzaffarpur	6.56	0.4	240	156	104	28.85	18.03	20	164	0.25	5.2	5	0.28	-	-	-
Desirable Limit **																						
Permissible Limit* in absence source (IS 10500-2012 - 2nd Revision																						
NR 5.0 2000 600 200 100 600 75 30 250 200 0.3 45 200 1.0 0.01 1 NR 400 1.5 NR -																						

As (1) Drinking Water Specification First Revision - IS 10500-2012, Edition 2, 2003-09, 12, 2010 (Reaffirmed 1993), (2) BDL - Below Detection Limit, (3) NR = No Relaxation, (4) ND = Not Done.

(a) Throughout any year, 95% of the samples should not contain coliform organisms in 100ml, (b) No sample should contain more than 10 coliform organisms per 100ml.

(c) Coliform organisms should not be detected in 100ml of any two consecutive samples.

By forwarded for information to: (i) Consultant Water Quality Cell, PHED, Govt. of Bihar, (ii) Director, Water Quality Cell, PHED, Govt. of Bihar, (iii) SWTL, PHED, Govt. of Bihar.

*In duly Compliance!*  
**MANAGER**  
**PRABHAT TARA SCHOOL**  
**CHAKKAR MAIDAN**  
**MUZAFFARPUR-842001**  
**(BIHAR)**

*[Signature]*  
 Executive Engineer,  
 Public Health Division, Muzaffarpur

*[Signature]*  
**Principal**  
**Prabhat Tara School**  
**Chakkar, Muzaffarpur**

*[Signature]*  
 04/08/2023  
 Chemist  
 R. W. T. L., Muzaffarpur