

**OFFICE OF THE EXECUTIVE ENGINEER
P.H. DIVISION, MUZAFFARPUR**

Letter No. : 49...../

Dated : 18.10.2025

REGARDING SAFE DRINKING WATER AND SANITARY CONDITION


CERTIFICATE

It is certified that an inspection team headed by **Sri Satya Prakash Azad, Chemist** from Public Health Division, Muzaffarpur (Name of Department/Office) inspected the **PRABHAT TARA SCHOOL, Chakkar Maidan, Kazi Mohammadpur, Muzaffarpur, Bihar 842001** (Name of School) has safe drinking water facilities for the students and memories of staff of the institution and is maintaining the hygienic by the central/state/U.T. Govt.

The above is valid for a period of one year.


Chemist 18/10/25
R.W.T.L., Muzaffarpur
CHEMIST
R.W.T.L; MUZAFFARPUR

To,
The Principal
PRABHAT TARA SCHOOL,
Chakkar Maidan, Kazi Mohammadpur,
Muzaffarpur, Bihar 842001


MANAGER
PRABHAT TARA SCHOOL
CHAKKAR MAIDAN
MUZAFFARPUR-842001


10/02/2026
Principal
Prabhat Tara School
Chakkar Maidan
Muzaffarpur (Bihar)

PUBLIC HEALTH ENGINEERING DEPARTMENT

Water Quality Report

Division Name :- P. H. Division, Muzaffarpur

District Name : Muzaffarpur

Month : August 2025

Name of the School :- PRABHAT TARA SCHOOL

Sl. No.	Testing Date	Block	Panchayat	Village	Habitation/Ward	Location of Source	pH	Turb.	Cond.	TDS	TH	Ca	Mg	Cl	Alk	Fe	No ₃	So ₄	F	As	Total Cell	Remarks
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23
1	18.08.2025	Mushahari	Nagar Nigam	Chakkar Maidan	-	Prabhat Tara School, Chakkar Maidan Muzaffarpur	7.12	1.0	204.00	120.00	64.00	16.24	4.21	20.00	110.00	0.3	0.95	10.00	0.2	-	-	
Desirable Limit **							6.5-8.5	1.0	-	500	200	75	30	250	200	0.3	45	200	1.0	0.01	-	
Permissible Limit* in absence source (IS 10500-2012 - 2nd Revision)							NR	5.0		2000	600	200	100	1000	600	1	NR	400	1.5	NR	-	

S. K. Singh
MANAGER
 PRABHAT TARA SCHOOL
 CHAKKAR MAIDAN
 MUZAFFARPUR-842001
 (BIHAR)

Al
 10/02/2026
Principal
 Prabhat Tara School
 Chakkar Maidan
 Muzaffarpur (Bihar)

S. K. Singh
 Chemist 8/08/25
R. W. T. L. Muzaffarpur
CHEMIST
 R.W.T.L. MUZAFFARPUR